ROY COOPER Governor ELIZABETH S. BISER Secretary RICHARD E. ROGERS, JR. Director



## Certified Mail 7022 1670 0000 9974 4336 Return Receipt Requested

August 4, 2023

Donald Ike McRee, Jr, County Manager Currituck County 153 Courthouse Rd Ste 110 Currituck, NC 27929

SUBJECT: NOTICE OF VIOLATION

Tracking Number: NOV-2023-LV-0538

Permit No. WQ0035706 Moyock Regional WWTP

**Currituck County** 

Dear Mr. McRee:

A review of the November 2022 Ground Water Monitoring Report (GW59) for the subject facility revealed the violation(s) indicated below:

## **Limit Exceedance Violation(s):**

Sample Location	Parameter	Date	Limit Value	Reported Value	l Type of Violation
MW-2	Nitrogen, Ammonia Total (as N) (00610)	11/30/2022	1,500	15,500	Limit Exceeded
MW-3	Nitrogen, Ammonia Total (as N) (00610)	11/30/2022	1,500	56,600	Limit Exceeded

Remedial actions, if not already implemented, should be taken to correct any noted problems. The Division of Water Resources may pursue enforcement actions for this and any additional violations. If the violations are of a continuing nature, not related to operation and/or maintenance problems, and you anticipate remedial construction activities, then you may wish to consider applying for a Special Order by Consent (SOC).

If you have any questions concerning this matter, please contact Robert Tankard at (252) 948-3921 or Randy Sipe at (252) 948-3849.

Sincerely,

## Robert Tankard

Robert Tankard, Assistant Regional Supervisor Water Quality Regional Operations Section Washington Regional Office Division of Water Resources, NCDEQ

Cc: Will Rumsey – Currituck County (electronic copy) Rod Holley – Currituck County (electronic copy) Laserfiche