

Currituck County

Wastewater Department

Rod Holley, Wastewater Superintendent



444 Maple Rd.
Maple NC 27956
Phone 252-232-6065
Fax 252-453-3721

Email: Rod.Holley@CurrituckCountyNC.gov

July 17, 2023

Subject: Notice of Violation Response

Tracking No. NOV-2023-LV-0484 and NOV-2023-LV-0485

Permit No. WQ0035706 Moyock Regional WWTP

Mr. Tankard:

In response to NOV-2023-LV-0484 for February 2023 and NOV-2023-LV-0485 for May 2023, the February report referenced in Notice of Violation was prior to the termination of, at the time, an ongoing contract with EnviroLink. As of May 1, 2023 the County took over operations of the Moyock Regional WWTP and filed the proper documentation for change of ORC Designation form. The plant was in total disarray with numerous nonfunctional and/or damaged monitoring devices that have been put back into service, repaired or replaced. Although the treatment process is not producing quality effluent, no influent overflows, no bypassing and a functional effluent flow meter is in working order. We are also feeding chemicals permitted to aid in nutrient removal and making every effort to produce the best effluent discharge as possible with what we have. I believe an update and pictures were being sent by Will Rumsey to show where we are in our efforts to clean up and operate the plant and repair the damage left behind. If you need more information or have further questions, feel free to contact us and we will be happy to discuss or elaborate in detail.

Thank You,

Rod Holley
Wastewater Superintendent Trainee
rod.holley@currituckcountync.gov
rec'd 7/12/23